

I MAIIN I	D711127107011 -				
LINE	TYPE "B"	TYPE "B" MOD.			
20"	33"	28" 31"			
24"	<i>36</i> "				
30"	39"	34"			
36"	43"	38"			

46"

49"

MANA

42"

48"

DIMENSION "L"

41"

44"

## NOTES:

- 1. FIRE HYDRANT SHALL HAVE A MAXIMUM BURY OF 7'-0". MODIFICATION OF THE HYDRANT LEAD TO MEET THIS REQUIREMENT SHALL BE IN THAT SECTION FROM THE VALVE TO THE HYDRANT AS PER STANDARD DETAIL L-7601.
- 2. FIRE HYDRANTS SHALL BE SET A MINIMUM OF 6' FROM ALL DRIVEWAY OPENINGS.
- 3. TEE USED TO CONNECT HYDRANT LEAD TO WATER MAIN IS INCLUDED IN COST OF ITEM 809, FIRE HYDRANT.

	CITY						
DEPAR'	CMENT	OF	PU	BLIC	UTIL	ITIES	
al de	⋑VIS	ION	OF	WAT	ER		
	7			7 7			

APPROVED:

RC Westerfield 5-15-13

ADMINISTRATOR DATE

STANDARD DETAIL

TYPICAL HYDRANT SETTING

TYPE "B" AND "B" MODIFIED

FOR CONCRETE AND STEEL PIPE



5409 B.Dwg Revision Date: 1/2/13